

Wyniki - Zestawienie pomieszczeń

Symbol	Opis	$\theta_{int,H}$	A	V	Φ_{HL}	n_{50}	$V_{su \min}$
		°C	m ²	m ³	W	1/h	m ³ /h
1.1	Bibioletka 1.1	20,0	107,40	384,5	5522	1	384,5
1.2	Pom. gosp. 1.2	20,0	6,41	22,9	326	1	22,9
1.3	Toaleta per. 1.3	20,0	3,33	11,9	358	1	50,0
1.4	Komunikacja 1.4	20,0	18,85	67,5	457	1	67,5
1.5	MOP 1.5	20,0	1,50	5,4	28	1	5,4
1.6	Pom. gosp. 1.6	20,0	6,00	21,5	111	1	21,5
1.7	Przebieralnia 1.7	24,0	2,80	10,0	440	1	10,0
1.8	Pom. socjalne 1.8	20,0	10,90	39,0	493	1	58,5
1.9	Toaleta. niepel. 1.9	20,0	5,00	17,9	525	1	50,0
1.10	Toaleta m. 1.10	20,0	2,70	9,7	390	1	50,0
1.11	Kotłownia 1.11	20,0	4,60	16,5	761	1	
1.12	Sala spodkan 1.12	20,0	58,85	210,7	4525	1	210,7
2.1	Czytelnia 2.1	20,0	81,93	245,8	3077	1	245,8
2.2	Archiwum 2.2	20,0	21,20	63,6	870	1	63,6
2.3	Pom. biurowe 2.3	20,0	16,25	48,8	792	1	48,8
2.4	Pom. biurowe 2.4	20,0	17,80	53,4	582	1	53,4